



Vermont Guide to Fluoride Levels in Public Water Systems and the Fluoride in Well Water Testing Program 2024 Edition

Prepared by the Office of Oral Health
Vermont Department of Health

August 19, 2024, Updated October 23, 2024

The Purpose of this Guide

This booklet provides information on the fluoride levels in public water systems in Vermont and information about Vermont's Fluoride in Well Water Testing Program. It's designed to help public health professionals, healthcare providers, and the public make informed decisions about oral health.

Community Water Fluoridation Systems

All water, including ground, surface, and sea water has fluoride, but the level is usually less than optimal to help prevent tooth decay. Community water fluoridation is the adjustment of natural fluoride levels to 0.70 mg/L; the optimal level to prevent tooth decay recommended by the U.S. Department of Health and Human Services (HHS).

Americans have access to more sources of fluoride than they did when water fluoridation was first introduced in the United States in the 1940s, including dental products such as toothpaste and mouth rinses, prescription fluoride supplements, and fluoride applied by dental or medical professionals. Water fluoridation and fluoride toothpaste are largely responsible for the significant decline in tooth decay in the U.S. over the past several decades. However, tooth decay is still a very common, chronic, preventable disease that affects all ages. Tooth decay impacts employment, social development, self-esteem, and overall quality of life. *To learn more about Fluoride in Vermont, visit the Health Department Fluoride webpage:*

<http://www.healthvermont.gov/wellness/oral-health/fluoride>

Table 1 summarizes public water systems in Vermont and their fluoride status.

Table 1: Number of Vermont's Public Water Systems by Category	
Category	Number of Systems
Fluoridated	
• Adjusted*	29
• Natural	5
• Consecutive**	31
Multi-Source	2
Non-Fluoridated	338
Total	405

***Adjusted (A):** A water system that adds fluoride to achieve an optimal fluoride level of 0.70 mg/L. [CDC Guidelines](#): "The CDC recommends an asymmetrical operational control range of 0.6 mg/L to 1.0 mg/L in order for public water systems to consistently meet the recommended concentration of 0.7 mg/L."

****Consecutive (C):** A water system that purchases water from another water system. The consecutive water system has a water plant but does little or no treatment to the water. These water systems are optimally fluoridated if the original (i.e., parent) system is optimally fluoridated. No additional fluoride is added to the consecutive system.

Table 2 lists Vermont water systems that fluoridate, and the year fluoridation was initiated.

Table 2: Water Systems in VT that Fluoridate and Year Initiated	
Alburgh Village Water System	2014
Barre City Water System	1968
Bellows Falls Water Department	1968
Bradford Village Water System	1971
Burlington Department of Public Works Water Division	1953
Champlain Water District	1973
Enosburg Falls Water System	1976
Hinesburg Water System	2000
Jericho Underhill Water System	1973
Ludlow Village Water System	1996
Middlebury Water System	1972
Montpelier Water System	1972
Morrisville Water and Light	1970
Newbury Village Water System	1987
Newport City Water System	1969
Northfield Water Department	1976
Norwich Fire District 1	1971
Orleans Water System	1969
Poultney Water Department	1978
Proctor Water Department	1963
Randolph Village Water System	1998
Richmond Water System	1983
Rutland City Water Department	1983
Springfield Water Department	1976
St. Albans Water Department	1983
St. Johnsbury Water System	1983
Swanton Village Water System	1969
Vergennes Panton Water System	1973
Waterbury (Edward Farrar Utility District)	1968

For Health Care Providers

Health Care Providers' responsibilities:

- Before prescribing fluoride supplements determine the existing fluoride content in a family's primary source of water (either through this guide or a test).
- Consider the water source for infants and children in daycare facilities and schools before prescribing supplements.
- Refer to the Dietary Fluoride Supplement Schedule for prescription guidelines (Table 3).

Table 3 gives the dietary fluoride supplement schedule for children through 16 years old:

Table 3: Fluoride Ion in Drinking Water (mg/L)			
Age	Less than 0.30 ppm	0.30–0.60 ppm	Greater than 0.60 ppm
Birth–6 months	No supplements	No supplements	No supplements
6 months–3 years	0.25 mg/day	No supplements	No supplements
3–6 years	0.50 mg/day	0.25 mg/day	No supplements
6–16 years	1.00 mg/day	0.50 mg/day	No supplements

Source: [American Academy of Pediatric Dentistry, 2023](#)

To obtain the benefits from fluoride supplements, long-term compliance daily is required.

Frequently Asked Questions:

1. Why test a private water supply?

It is important that prescriptions are **not** written for children who may already be receiving high levels of naturally fluoridated water. If a family gets their water from a private water source, the only way to know whether a child needs a fluoride prescription is to test the water for its level of natural fluoride **before** prescriptions for supplements are written. There are areas in Vermont where the naturally occurring fluoride level in the groundwater exceeds the secondary contaminant level for fluoride (2.0 mg/L). In this case, the Health Department recommends a reverse osmosis water filtration system to reduce fluoride exposure.

2. How do I test a private water supply?

The Health Department Laboratory will test fluoride for free in small systems, well water or springs for families with children ages four years or younger through the **Fluoride in Well Water Testing Program**. The Public Health Laboratory will test fluoride levels for a fee for families with children ages four or older. Any other certified laboratory for water analysis can also test for fluoride levels.

3. If I have a patient with a private water supply and a child under age four, where can I get a copy of the Fluoride in Well Water Test Form?

To access the Fluoride in Well Water Test Form, visit:

<https://www.healthvermont.gov/sites/default/files/document/hpdp-fluorideinwellwaterform.pdf>

4. What else should people who drink water from private water systems test their water for?

If you are on a private well or spring, the Health Department recommends testing your water regularly using these three test kits, called the Vermont Homeowner Testing Package:

- Total coliform and *E.coli* bacterial test **every year**
- Inorganic chemicals test every **five years**
- Gross alpha radiation screening every **five years**

You can order the **Vermont Homeowner Testing Package** for \$159 or individual drinking water test kits from the Health Department Laboratory at (800) 660-9997 or (802) 338-4724 – or use another certified drinking water lab.

To order a kit online or for more information on drinking water testing visit:

<http://www.healthvermont.gov/water/testing>

5. How much fluoride is in public water systems in Vermont?

Please see Table 4 below.

Fluoride Levels in Public Water Systems in Vermont

The following table (Table 4) includes information about fluoride levels in Vermont's 405 active public water systems. The data was obtained from the Vermont Department of Environmental Conservation's Drinking Water and Groundwater Protection Division on June 18, 2024. Systems that have fluoridated water (either adjusted or consecutive) have an asterisk in the Fluoride Level column of the table.

[Vermont's Water Supply Rule](#) states that: "Public water systems which add fluoride to drinking water for dental health purposes, in addition to complying with the maximum contaminant levels established in Subchapter 21–6, shall control the level of fluoride in accordance with current Centers for Disease Control and Prevention guidelines."

[CDC Guidelines](#): "The CDC recommends an asymmetrical operational control range of 0.6 mg/L to 1.0 mg/L in order for public water systems to consistently meet the recommended concentration of 0.7 mg/L."

How to interpret Table 4: Water systems (WS) in Table 4 are organized by county and categorized as adjusted, consecutive, multi-source, natural, or non-adjusted (descriptions below). The fluoride level column of adjusted and consecutive systems contains an asterisk (*). The fluoride level column of natural systems contains the most current test result. The fluoride level column of non-adjusted systems contains the most current test result or the detection limit, and whether or not the test result was under that limit (i.e., undetectable). The category column of the 338 non-adjusted systems is left blank.

For the most up-to-date level of fluoride, check with the water system or the annual water quality report. If you have any questions about Table 4, please email ahs.vdhoralhealth@vermont.gov.

Categories in Table 4:

***Adjusted (A):** A water system that adds fluoride to achieve an optimal fluoride level of 0.70 mg/L. [CDC Guidelines](#): "The CDC recommends an asymmetrical operational control range of 0.6 mg/L to 1.0 mg/L in order for public water systems to consistently meet the recommended concentration of 0.7 mg/L." There are 29 adjusted water systems in Vermont.

***Consecutive (C):** A water system that purchases water from another water system that has fluoridated water. These water systems are optimally fluoridated if the original (i.e., parent) system is optimally fluoridated. There are 31 consecutive water systems in Vermont that purchase water from an adjusted system.

Multi-Source (MS): A water system that gets water from various sources, including at least one that is fluoridated. Fluoride levels vary based on the source. There are two multi-source systems in Vermont (Barre Town, and Graniteville FD 4).

Natural (N): A water system with a natural fluoride concentration at or above 0.60 mg/L. No fluoride is added to the system. There are five natural systems in Vermont.

Non-adjusted (left blank): A water system with a natural fluoride level at or below 0.59 mg/L. No fluoride is added. There are 338 non-adjusted systems in Vermont.

Table 4: Fluoride Levels in Public Water Systems in Vermont

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
ADDISON	TRI TOWN WATER DISTRICT	BRIDPORT		0.1	Y	
ADDISON	BRISTOL WATER DEPT	BRISTOL		0.1	Y	
ADDISON	EAST MIDDLEBURY FD 1	MIDDLEBURY		0.1	Y	
ADDISON	MIDDLEBURY WATER DEPT	MIDDLEBURY	*			A
ADDISON	STARSBORO VILLAGE WATER COOP	STARSBORO		0.1	Y	
ADDISON	BROOKSIDE MHP	STARSBORO		0.1	Y	
ADDISON	LAZY BROOK MHP	STARSBORO		0.1	Y	
ADDISON	VERGENNES PANTON WATER DISTRICT	VERGENNES	*			A
ADDISON	WHITING WATER CORP	WHITING		0.1	Y	
BENNINGTON	ARLINGTON WATER DEPT	ARLINGTON		0.1	Y	
BENNINGTON	BENNINGTON WATER DEPT	BENNINGTON		0.1	Y	
BENNINGTON	NORTH BENNINGTON WATER DEPT	BENNINGTON		0.1	Y	
BENNINGTON	WEST ROAD MHP	BENNINGTON		0.2	Y	
BENNINGTON	DORSET FIRE DISTRICT 1	DORSET		0.1	Y	
BENNINGTON	EAST DORSET FIRE DISTRICT 1	DORSET		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
BENNINGTON	MANCHESTER WATER DEPT	MANCHESTER		0.1	Y	
BENNINGTON	MANCHESTER MHP	MANCHESTER		0.1	Y	
BENNINGTON	BROMLEY WATER COMPANY	PERU		0.1	Y	
BENNINGTON	LAMPMAN WATER SYSTEM	POWNA		0.1	Y	
BENNINGTON	ROYAL PINE VILLA	POWNA		0.2	Y	
BENNINGTON	READSBORO TOWN OF	READSBORO		0.1	Y	
BENNINGTON	SHAFTSBURY WATER SYSTEM	SHAFTSBURY		0.2	Y	
BENNINGTON	GORE ROAD MHP	BENNINGTON		0.2	Y	
BENNINGTON	POWNA FIRE DISTRICT 3	POWNA		0.2	Y	
BENNINGTON	PIPER RIDGE CONDOMINIUM	WINHALL		0.1	Y	
BENNINGTON	POWNA ESTATES MHP, LLC.	POWNA		0.2	Y	
BENNINGTON	WINHALL ACRES	WINHALL		0.1	Y	
BENNINGTON	INTERVALE AT STRATTON	WINHALL		0.1	Y	
BENNINGTON	EVERGREEN MHP	POWNA		0.1	Y	
BENNINGTON	VILLAGE AT EAGLE RISE	MANCHESTER		0.1	Y	
BENNINGTON	VILLAGE AT ORMSBY HILL HOA	MANCHESTER		0.1	Y	
BENNINGTON	BENNINGTON COLLEGE	BENNINGTON	0.2	0	N	
BENNINGTON	MOUNTAIN VIEW COURT	BENNINGTON				
BENNINGTON	POWNA FIRE DISTRICT 2	POWNA		0.1	Y	
BENNINGTON	EAST MOUNTAIN MHP	BENNINGTON				
BENNINGTON	WILLOWS MHP	BENNINGTON				

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
BENNINGTON	100 MOUNTAIN VIEW ROAD PARK	BENNINGTON				
BENNINGTON	WHITE BIRCHES MHP	BENNINGTON				
BENNINGTON	DORSET COMMUNITY HOUSING	DORSET		0.00475	Y	
BENNINGTON	STRATTON WEST LEISURE LODGE CORPORATION	WINHALL		0.1	Y	
CALEDONIA	BARNET FIRE DISTRICT #2	BARNET		0.1	Y	
CALEDONIA	PASSUMPSIC FIRE DISTRICT 1	BARNET	*			C
CALEDONIA	BURKE FIRE DISTRICT 1	BURKE		0.1	Y	
CALEDONIA	DANVILLE FIRE DISTRICT 1	DANVILLE	0.2	0.1	N	
CALEDONIA	EAST HARDWICK FIRE DISTRICT 1	HARDWICK		0.1	Y	
CALEDONIA	HARDWICK TOWN WATER SYSTEM	HARDWICK		0.1	Y	
CALEDONIA	LYNDONVILLE WATER SYSTEM	LYNDON		0.1	Y	
CALEDONIA	LYN HAVEN FIRE DISTRICT 1	LYNDON	0.11	0.1	N	
CALEDONIA	PEACHAM FIRE DISTRICT 1	PEACHAM		0.1	Y	
CALEDONIA	RYEGATE FIRE DISTRICT 2	RYEGATE	0.1	0.1	N	
CALEDONIA	ST JOHNSBURY WATER SYSTEM	SAINT JOHNSBURY	*			A
CALEDONIA	ST JOHNSBURY CENTER F D 1	SAINT JOHNSBURY	*			C
CALEDONIA	SUTTON WATER SYSTEM	SUTTON		0.1	Y	
CALEDONIA	WHEELOCK FIRE DISTRICT 1	WHEELOCK		0.1	Y	
CALEDONIA	SHEFFIELD FIRE DISTRICT 1	SHEFFIELD		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
CALEDONIA	MCINDOE FALLS FIRE DISTRICT 3	BARNET		0.1	Y	
CALEDONIA	BURKE MOUNTAIN WATER CO	BURKE	0.47	0.1	N	
CALEDONIA	KARME CHOLING	BARNET	0.51	0.1	N	
CALEDONIA	WEST BURKE HOUSING	BURKE	0.28	0.1	N	
CALEDONIA	NORTHEAST KINGDOM MHP	LYNDON				
CHITTENDEN	BOLTON COMMUNITY WATER SYSTEM	BOLTON		0.1	Y	
CHITTENDEN	FERNWOOD MANOR MHP	BOLTON		0.1	Y	
CHITTENDEN	BURLINGTON DEPT PUBLIC WORKS WATER DIV	BURLINGTON	*			A
CHITTENDEN	PINE RIDGE WATER SYSTEM	CHARLOTTE	0.26	0.1	N	
CHITTENDEN	HILLCREST MHP INC	COLCHESTER	*			C
CHITTENDEN	COLCHESTER FIRE DISTRICT 1	COLCHESTER	*			C
CHITTENDEN	COLCHESTER FIRE DISTRICT 2	COLCHESTER	*			C
CHITTENDEN	COLCHESTER FIRE DISTRICT 3	COLCHESTER	*			C
CHITTENDEN	ESSEX TOWN WATER SYSTEM	ESSEX	*			C
CHITTENDEN	ESSEX JCT WATER DEPT	ESSEX	*			C
CHITTENDEN	HINESBURG WATER DEPT	HINESBURG	*			A
CHITTENDEN	HUNTINGTON FIRE DISTRICT 1	HUNTINGTON		0.1	Y	
CHITTENDEN	VILLAGE OF JERICHO WATER SYSTEM	JERICHO	*			C
CHITTENDEN	JERICHO HEIGHTS WATER COOP	JERICHO	0.22	0.1	N	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
CHITTENDEN	MILTON WATER DEPT	MILTON	*			C
CHITTENDEN	MILTON MOBILE HOME PARK	MILTON	*			C
CHITTENDEN	RICHMOND WATER DEPT	RICHMOND	*			A
CHITTENDEN	RIVERVIEW COMMONS	RICHMOND		0.1	Y	
CHITTENDEN	SHELBURNE WATER DEPT	SHELBURNE	*			C
CHITTENDEN	LIVINGSTON MHP	SHELBURNE	*			C
CHITTENDEN	SOUTH BURLINGTON FIRE DISTRICT	SOUTH BURLINGTON	0.17	0.1	N	
CHITTENDEN	SOUTH BURLINGTON CITY WATER SYSTEM	SOUTH BURLINGTON	*			C
CHITTENDEN	CHAMPLAIN WATER DISTRICT	SOUTH BURLINGTON	*			A
CHITTENDEN	ST GEORGE FIRE DISTRICT 1	SAINT GEORGE		0.1	Y	
CHITTENDEN	ST GEORGE FIRE DISTRICT #2	SAINT GEORGE		0.1	Y	
CHITTENDEN	ST GEORGE COMMUNITY COOPERATIVE	SAINT GEORGE		0.1	Y	
CHITTENDEN	JERICO UNDERHILL WATER	UNDERHILL	*			A
CHITTENDEN	WILLISTON WATER DEPT	WILLISTON	*			C
CHITTENDEN	WILLISTON FIRE DISTRICT 1	WILLISTON		0.1	Y	
CHITTENDEN	WINOOSKI WATER DEPT	WINOOSKI	*			C
CHITTENDEN	RICHMOND FIRE DISTRICT 1	RICHMOND	0.13	0.1	N	
CHITTENDEN	WESTFORD FIRE DISTRICT 1	WESTFORD		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
CHITTENDEN	JERICO FIRE DISTRICT 1	JERICO		0.1	Y	
CHITTENDEN	WILDWOOD WEST	CHARLOTTE	1	0.1	N	N
CHITTENDEN	SUNNY ACRES DEVELOPMENT WATER ASSOC INC	MILTON	0.35	0.1	N	
CHITTENDEN	WEST WIND WATER SYSTEM	CHARLOTTE		0.1	Y	
CHITTENDEN	SHELBURNE FARMS	SHELBURNE	*			C
CHITTENDEN	COUNTRY CLUB CONDOMINIUM	BOLTON		0.1	Y	
CHITTENDEN	JERICO EAST HOME OWNERS ASSOCIATION	JERICO	*			C
CHITTENDEN	CHIMNEY HILL COLCHESTER	COLCHESTER	0.34	0.1	N	
CHITTENDEN	LYMAN MEADOWS	HINESBURG	0.11	0.1	N	
CHITTENDEN	NORTH HARBOR	COLCHESTER	0.22	0.1	N	
CHITTENDEN	ORCHARD COMMONS	HINESBURG	0.16	0.1	N	
CHITTENDEN	MALLETTS BAY WATER CO	COLCHESTER	*			C
CHITTENDEN	WAKE ROBIN CORP	SHELBURNE	*			C
CHITTENDEN	WESTBURY PARK	COLCHESTER	*			C
CHITTENDEN	WINDEMERE MHP	COLCHESTER	*			C
CHITTENDEN	OAK HILL ESTATES WATER SYSTEM	WILLISTON	*			C
CHITTENDEN	COMMON PASTURES HOA	CHARLOTTE	0.26	0.00475	N	
CHITTENDEN	NORTH AVE CO-OP	BURLINGTON	*			C
ESSEX	BLOOMFIELD WATER SYSTEM	BLOOMFIELD	0.37	0	N	
ESSEX	BRIGHTON WATER SYSTEM	BRIGHTON	0.1	0.1	N	
ESSEX	CANAAN FIRE DISTRICT 1	CANAAN		0.3	Y	
ESSEX	CANAAN FD #2	CANAAN		0.1	Y	
ESSEX	AQUA HAVEN	EAST HAVEN	0.81	0.1	N	N

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
ESSEX	GUILDHALL WATER SYSTEM	GUILDHALL		0.2	Y	
ESSEX	LUNENBURG FIRE DISTRICT 1	LUNENBURG	0.14	0.1	N	
ESSEX	LUNENBURG FIRE DISTRICT 2	LUNENBURG		0.1	Y	
ESSEX	CONCORD ESTATES MHP, LLC.	CONCORD		0.2	Y	
FRANKLIN	BAKERSFIELD FIRE DISTRICT 1	BAKERSFIELD		0.1	Y	
FRANKLIN	EAST BERKSHIRE FIRE DISTRICT 1	BERKSHIRE		0.1	Y	
FRANKLIN	ENOSBURG FALLS WATER SYSTEM	ENOSBURGH	*			A
FRANKLIN	FAIRFAX WATER DEPT	FAIRFAX		0.1	Y	
FRANKLIN	FAIRFAX HEIGHTS WATER CO	FAIRFAX		0.1	Y	
FRANKLIN	EAST FAIRFIELD FIRE DISTRICT 1	FAIRFIELD		0.1	Y	
FRANKLIN	FRANKLIN WATER SYSTEM	FRANKLIN		0.1	Y	
FRANKLIN	SOUTH GEORGIA FIRE DISTRICT	GEORGIA	0.15	0.1	N	
FRANKLIN	MONTGOMERY WATER SYSTEM	MONTGOMERY		0.1	Y	
FRANKLIN	RICHFORD WATER SYSTEM	RICHFORD		0.1	Y	
FRANKLIN	SHELDON WATER SYSTEM	SHELDON		0.1	Y	
FRANKLIN	ST ALBANS WATER DEPT	SAINT ALBANS CITY	*			A
FRANKLIN	SWANTON VILLAGE WATER	SWANTON	*			A
FRANKLIN	SUNSET TERRACE ESTATES	SWANTON		0.1	Y	
FRANKLIN	HOMESTEAD ACRES MHP	SWANTON	0.11	0.1	N	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
FRANKLIN	RHODESIDE ACRES	GEORGIA	0.14	0.1	N	
FRANKLIN	FAIRFAX FIRE DISTRICT 1	FAIRFAX		0.1	Y	
FRANKLIN	GEORGIA STATION	GEORGIA	0.36	0.1	N	
FRANKLIN	DAIRY CENTER	ENOSBURGH	0.13	0.1	N	
FRANKLIN	FAIRFIELD FIRE DISTRICT 2	FAIRFIELD		0.1	Y	
FRANKLIN	COLONIAL ESTATES HOMEOWNERS ASSN	FAIRFAX	0.16	0.1	N	
FRANKLIN	EASTFIELD CONDOMINIUM ASSN INC	FAIRFAX	0.11	0.1	N	
GRAND ISLE	ALBURGH VILLAGE WATER SYSTEM	ALBURGH	*			A
GRAND ISLE	ALBURGH FIRE DISTRICT 1	ALBURGH		0.1	Y	
GRAND ISLE	GRAND ISLE FIRE DISTRICT 4	GRAND ISLE		0.1	Y	
GRAND ISLE	SOUTH HERO FIRE DISTRICT 4	SOUTH HERO		0.1	Y	
GRAND ISLE	NORTH HERO WATER SYSTEM	NORTH HERO		0.1	Y	
GRAND ISLE	GRAND ISLE CONSOLIDATED WATER DISTRICT	GRAND ISLE		0.1	Y	
GRAND ISLE	SOUTH ALBURGH FIRE DISTRICT 2	ALBURGH	*			C
LAMOILLE	CAMBRIDGE VILLAGE WATER	CAMBRIDGE		0.1	Y	
LAMOILLE	JEFFERSONVILLE WATER SYSTEM	CAMBRIDGE		0.1	Y	
LAMOILLE	SMUGGLERS NOTCH WATER SYSTEM	CAMBRIDGE	0.25	0.1	N	
LAMOILLE	ELMORE WATER DISTRICT	ELMORE		0.1	Y	
LAMOILLE	HYDE PARK FIRE DISTRICT 1	HYDE PARK		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
LAMOILLE	HYDE PARK WATER SYSTEM	HYDE PARK		0.1	Y	
LAMOILLE	MOUNTAIN VIEW MHP	JOHNSON		0.1	Y	
LAMOILLE	JOHNSON VILLAGE WATER DEPT	JOHNSON		0.1	Y	
LAMOILLE	MORRISTOWN CORNER WATER CORP	MORRISTOWN	0.35	0.1	N	
LAMOILLE	MORRISVILLE WATER AND LIGHT	MORRISTOWN	*			A
LAMOILLE	PINECREST MOBILE HOME PARK	MORRISTOWN		0.1	Y	
LAMOILLE	STOWE WATER DEPT	STOWE		0.1	Y	
LAMOILLE	MOUNTAINSIDE RESORT	STOWE		0.1	Y	
LAMOILLE	STOWE F D 2 GOLD BROOK CIRCLE	STOWE		0.1	Y	
LAMOILLE	WATERVILLE FIRE DISTRICT 1	WATERVILLE		0.1	Y	
LAMOILLE	MANSFIELD VIEW WATER CORP	STOWE		0.1	Y	
LAMOILLE	STOWE FIRE DISTRICT 4	STOWE	0.23	0.1	N	
LAMOILLE	RIVER ROAD APARTMENTS	STOWE		0.1	Y	
LAMOILLE	NOTCHBROOK CONDOMINIUM	STOWE		0.1	Y	
LAMOILLE	BIRCH HILL WATER SYSTEM	STOWE		0.1	Y	
LAMOILLE	STERLING VIEW COOPERATIVE COMMUNITY INC	HYDE PARK	0.1	0.1	N	
LAMOILLE	COVERED BRIDGE HIGHLAND	STOWE	0.11	0.1	N	
LAMOILLE	NOTCHBROOK III	STOWE		0.1	Y	
ORANGE	BRADFORD VILLAGE WATER SYSTEM	BRADFORD	*			A

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
ORANGE	MOBILE ACRES MHP	BRAINTREE		0.1	Y	
ORANGE	FAIRLEE TOWN WATER	FAIRLEE		0.1	Y	
ORANGE	NEWBURY VILLAGE INC	NEWBURY	*			A
ORANGE	WELLS RIVER WATER SYSTEM	NEWBURY		0.1	Y	
ORANGE	RANDOLPH CENTER WATER SYSTEM	RANDOLPH		0.1	Y	
ORANGE	RANDOLPH VILLAGE	RANDOLPH	*			A
ORANGE	ARMSTRONGS MHP	RANDOLPH		0.1	Y	
ORANGE	THETFORD WATER COOP INC	THETFORD		0.1	Y	
ORANGE	UNION WATER CO	THETFORD		0.1	Y	
ORANGE	EAST THETFORD WATER CO	THETFORD		0.1	Y	
ORANGE	WASHINGTON FIRE DISTRICT	WASHINGTON	0.14	0.1	N	
ORANGE	WILLIAMSTOWN WATER DEPT	WILLIAMSTOWN		0.1	Y	
ORANGE	WEST FAIRLEE MHP	WEST FAIRLEE		0.1	Y	
ORANGE	GREENES MHP	RANDOLPH		0.1	Y	
ORANGE	WASHINGTON NORTH MHP	WASHINGTON		0.1	Y	
ORANGE	LIMEHURST MHP	WILLIAMSTOWN		0.1	Y	
ORANGE	CHELSEA ELDERLY HOUSING	CHELSEA	0.4	0.3	N	
ORANGE	CHELSEA FAMILY HOUSING	CHELSEA		0.1	Y	
ORANGE	CHELSEA WATER SYSTEM	CHELSEA		0.1	Y	
ORLEANS	ALBANY WATER SYSTEM	ALBANY	0.13	0.1	N	
ORLEANS	BARTON WATER SYSTEM	BARTON		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
ORLEANS	ORLEANS WATER SYSTEM	BARTON	*			A
ORLEANS	COVENTRY FIRE DISTRICT 1	COVENTRY		0.1	Y	
ORLEANS	CRAFTSBURY FIRE DISTRICT 2	CRAFTSBURY	0.23	0.1	N	
ORLEANS	DERBY CENTER WATER SYSTEM	DERBY		0.1	Y	
ORLEANS	GREENSBORO FIRE DISTRICT 1	GREENSBORO		0.1	Y	
ORLEANS	GREENSBORO BEND FIRE DISTRICT #2	GREENSBORO		0.1	Y	
ORLEANS	IRASBURG FD #1	IRASBURG		0.1	Y	
ORLEANS	JAY PEAK SUBDIVISION II	JAY		0.1	Y	
ORLEANS	NEWPORT CITY WATER SYSTEM	NEWPORT CITY	*			A
ORLEANS	NEWPORT CENTER WATER SYSTEM	NEWPORT TOWN	0.19	0.1	N	
ORLEANS	NORTH TROY WATER SYSTEM	TROY		0.1	Y	
ORLEANS	TROY WATER SYSTEM	TROY		0.1	Y	
ORLEANS	WESTFIELD FIRE DISTRICT 1	WESTFIELD		0.1	Y	
ORLEANS	ALPINE HAVEN	WESTFIELD	0.12	0.1	N	
ORLEANS	UNION HOUSE NURSING HOME	GLOVER		0.1	Y	
ORLEANS	JAY PEAK WATER SYSTEM	JAY	0.2	0.1	N	
ORLEANS	MAPLE LANE NURSING HOME	BARTON		0.1	Y	
ORLEANS	HOLBROOK BAY COMMONS	NEWPORT TOWN	0.16	0.1	N	
ORLEANS	DERBY LINE VILLAGE WATER DISTRICT	DERBY		0.1	Y	
ORLEANS	SHATTUCK HILL MHP	DERBY				

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
ORLEANS	DERBY MHP	DERBY				
RUTLAND	VISTA SENIOR LIVING	MENDON	0.1	0.1	N	
RUTLAND	BRANDON FIRE DISTRICT 1	BRANDON		0.1	Y	
RUTLAND	CASTLETON FIRE DISTRICT 1	CASTLETON		0.1	Y	
RUTLAND	FORT WARREN MHP	CASTLETON		0.1	Y	
RUTLAND	DANBY MOUNT TABOR F D 1	DANBY		0.1	Y	
RUTLAND	FAIR HAVEN WATER DEPT	FAIR HAVEN		0.1	Y	
RUTLAND	EASTRIDGE ACRES ASSOCIATION	MENDON		0.1	Y	
RUTLAND	EAST MOUNTAIN WATER CORP	MENDON	0.14	0.1	N	
RUTLAND	PITTSFORD FLORENCE WATER DEPT	PITTSFORD		0.1	Y	
RUTLAND	POULTNEY WATER DEPT	POULTNEY	*			A
RUTLAND	PROCTOR WATER DEPT	PROCTOR	*			A
RUTLAND	RUTLAND CITY WATER DEPT	RUTLAND CITY	*			A
RUTLAND	GRANDVIEW ACRES WATER COOP	RUTLAND TOWN		0.1	Y	
RUTLAND	PICO VILLAGE WATER CORP	KILLINGTON		0.1	Y	
RUTLAND	HEMLOCK RIDGE CONDOMINIUM	KILLINGTON	0.12	0.1	N	
RUTLAND	CUTTINGSVILLE FIRE DISTRICT	SHREWSBURY	0.11	0.1	N	
RUTLAND	WALLINGFORD FIRE DISTRICT 1	WALLINGFORD		0.1	Y	
RUTLAND	SOUTH WALLINGFORD WATER CO	WALLINGFORD		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
RUTLAND	WEST RUTLAND TOWN	WEST RUTLAND		0.1	Y	
RUTLAND	COBURN MHP	CLARENDON		0.1	Y	
RUTLAND	RUTLAND TOWN FIRE DISTRICT 6	RUTLAND TOWN		0.1	Y	
RUTLAND	EDGEMONT CONDOMINIUMS	KILLINGTON		0.1	Y	
RUTLAND	WHIFFLETREE CONDOMINIUM	KILLINGTON		0.1	Y	
RUTLAND	RUTLAND TOWN FIRE DISTRICT 5	RUTLAND TOWN		0.1	Y	
RUTLAND	COLONIAL ESTATES WATER CORP	RUTLAND TOWN		0.1	Y	
RUTLAND	CASTLETON MEADOWS	CASTLETON		0.04	Y	
RUTLAND	RUTLAND TOWN FIRE DISTRICT 1	RUTLAND TOWN		0.1	Y	
RUTLAND	MOUNTAIN GREEN CONDOMINIUM	KILLINGTON		0.1	Y	
RUTLAND	PINNACLE CONDOMINIUM	KILLINGTON		0.1	Y	
RUTLAND	BENSON HEIGHTS	BENSON		0.1	Y	
RUTLAND	TELEMARK VILLAGE	KILLINGTON	0.14	0.1	N	
RUTLAND	SPRING LAKE RANCH INC	SHREWSBURY		0.1	Y	
RUTLAND	MOON RIDGE CONDOMINIUM	KILLINGTON	0.11	0.1	N	
RUTLAND	PARSONS HILL PARTNERSHIP	CASTLETON	0.11	0	N	
RUTLAND	HIGH RIDGE CONDOMINIUM	KILLINGTON		0.1	Y	
RUTLAND	WINDY HOLLOW	CASTLETON	0.22	0.1	N	
RUTLAND	TRAIL CREEK CONDOMINIUM	KILLINGTON		0.1	Y	
RUTLAND	WINTERGREEN AT KILLINGTON	PITTSFIELD		0.1	Y	
RUTLAND	NORTHSIDE CONDOMINIUM	KILLINGTON		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
RUTLAND	SUNRISE COMMUNITY WATER SYSTEM	KILLINGTON	0.17	0.1	N	
RUTLAND	GLAZE BROOK	KILLINGTON		0.1	Y	
RUTLAND	VALLEY PARK CONDOMINIUM	KILLINGTON		0.1	Y	
RUTLAND	WOODS AT KILLINGTON	KILLINGTON		0.1	Y	
RUTLAND	KILLINGTON UPLAND WATER CO INC	KILLINGTON		0.1	Y	
RUTLAND	FALL LINE TOWN HOUSES	KILLINGTON		0.1	Y	
RUTLAND	RUTLAND TOWN FIRE DISTRICT 4	RUTLAND TOWN	*			C
RUTLAND	CASTLETON FIRE DISTRICT 3	CASTLETON				
RUTLAND	RUTLAND TOWN FIRE DISTRICT 11	RUTLAND TOWN	*			C
RUTLAND	WINTERBERRY CONDOS	KILLINGTON		0.1	Y	
RUTLAND	HERITAGE HILL ASSOCIATION	RUTLAND TOWN	*			C
RUTLAND	MEADOWS - GABLES I WATER SYSTEM	RUTLAND TOWN	*			C
RUTLAND	KILLINGTON GATEWAY I CONDO ASSOCIATION	MENDON		0.1	Y	
RUTLAND	KILLINGTON GATEWAY II CONDO ASSOC INC	KILLINGTON		0.1	Y	
RUTLAND	GABLES II WATER SYSTEM	RUTLAND TOWN	*			C
WASHINGTON	WEBSTERVILLE WATER SYSTEM	BARRE TOWN		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
WASHINGTON	GRANITEVILLE FIRE DISTRICT 4	BARRE TOWN	varies based on source			MS
WASHINGTON	BIRCHWOOD PARK	BARRE TOWN		0.1	Y	
WASHINGTON	BARRE CITY WATER SYSTEM	BARRE CITY	*			A
WASHINGTON	BERLIN WATER CO INC	BERLIN		0.1	Y	
WASHINGTON	WESTONS MOBILE HOME PARK	BERLIN		0.1	Y	
WASHINGTON	CABOT TOWN WATER SYSTEM	CABOT	0.11	0.1	N	
WASHINGTON	EAST CALAIS FIRE DISTRICT 1	CALAIS		0.1	Y	
WASHINGTON	CRYSTAL SPRINGS WATER SYSTEM	EAST MONTPELIER		0.1	Y	
WASHINGTON	SANDY PINES MHP	EAST MONTPELIER		0.1	Y	
WASHINGTON	SUGAR RUN ASSOCIATION INC	FAYSTON		0.1	Y	
WASHINGTON	MARSHFIELD WATER SYSTEM	MARSHFIELD	0.21	0.1	N	
WASHINGTON	MONTPELIER WATER SYSTEM	MONTPELIER	*			A
WASHINGTON	NORTHFIELD WATER DEPT	NORTHFIELD	*			A
WASHINGTON	PLAINFIELD WATER SYSTEM	PLAINFIELD		0.1	Y	
WASHINGTON	BUTTERNUT HILL	WAITSFIELD		0.1	Y	
WASHINGTON	MOUNTAIN WATER COMPANY	WARREN		0.1	Y	
WASHINGTON	DRUMLEYS CONDOMINIUMS	WARREN		0.3	Y	
WASHINGTON	BRIDGES RESORT	WARREN	0.22	0.1	N	
WASHINGTON	EDWARD FARRAR UTILITY DISTRICT (Waterbury)	WATERBURY	*			A

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
WASHINGTON	EAST WIND MHP	WATERBURY		0.1	Y	
WASHINGTON	WORCESTER FIRE DISTRICT 1	WORCESTER	0.11	0.1	N	
WASHINGTON	RMC MOBILE HOME PARK	BERLIN		0.1	Y	
WASHINGTON	BATTLEGROUND CONDOMINIUM	FAYSTON	0.25	0.1	N	
WASHINGTON	COMMONS	MORETOWN		0.1	Y	
WASHINGTON	TIMBERLINE CONDOMINIUM ASSOCIATION	WARREN	0.13	0.1	N	
WASHINGTON	RIVERSIDE MHP	MORETOWN		0.1	Y	
WASHINGTON	FIDDLEHEAD CONDOMINIUMS	FAYSTON		0.1	Y	
WASHINGTON	SNOWSIDE CONDOMINIUM	FAYSTON	0.18	0.1	N	
WASHINGTON	STERLING RIDGE WATER	WARREN	0.19	0.1	N	
WASHINGTON	BERLIN HEALTH REHABILITATION CTR	BERLIN		0.1	Y	
WASHINGTON	BARRE TOWN WATER SYSTEM	BARRE TOWN	varies based on source			MS
WASHINGTON	CHRISTMAS TREE - SUNDOWN CONDOMINIUM	WARREN		0.1	Y	
WASHINGTON	SOUTH VILLAGE	WARREN		0.1	Y	
WASHINGTON	FLY IN WATER SYSTEM	WAITSFIELD	0.18	0.1	N	
WASHINGTON	SOUTHFACE	WARREN		0.1	Y	
WASHINGTON	CLUB SUGARBUSH WATER SYSTEM	WARREN	0.12	0.1	N	
WASHINGTON	CENTRAL VERMONT MEDICAL CENTER	BERLIN	*			C

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
WASHINGTON	FARMS AT CLUB SUGARBUSH	WARREN		0.1	Y	
WASHINGTON	WAITSFIELD WATER SUPPLY	WAITSFIELD	0.15	0.1	N	
WASHINGTON	WHEELER BROOK HOUSING DEVELOPMENT	WARREN		0.3	Y	
WASHINGTON	BERLIN MUNICIPAL WATER SYSTEM	BERLIN		0.1	Y	
WASHINGTON	NORTHWOODS VILLAGE APARTMENTS	EAST MONTPELIER				
WINDHAM	BRATTLEBORO WATER DEPT	BRATTLEBORO		0.1	Y	
WINDHAM	MOUNT SNOW VILLAGE ASSOCIATION	DOVER		0.1	Y	
WINDHAM	MAGIC VILLAGE WATER COOP	LONDONDERRY		0.1	Y	
WINDHAM	BELLOWS FALLS WATER DEPT	ROCKINGHAM	*			A
WINDHAM	VERMONT ACADEMY	ROCKINGHAM		0.1	Y	
WINDHAM	NORTHSHORE MHP	ROCKINGHAM		0.1	Y	
WINDHAM	WINHALL STRATTON F D 1	STRATTON		0.1	Y	
WINDHAM	WESTMINSTER AQUEDUCT SOCIETY	WESTMINSTER		0.1	Y	
WINDHAM	SHADY PINES MHP	WESTMINSTER		0.1	Y	
WINDHAM	WILMINGTON WATER DIST	WILMINGTON		0.2	Y	
WINDHAM	CHIMNEY HILL	WILMINGTON		0.1	Y	
WINDHAM	COLD BROOK FIRE DISTRICT 1	WILMINGTON		0.1	Y	
WINDHAM	WARNER PLACE WATER SYSTEM	ROCKINGHAM	0.11	0.1	N	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
WINDHAM	NEW ENGLAND KURN HATTIN HOMES	WESTMINSTER	1.5	0	N	N
WINDHAM	VERNON GREEN NURSING HOME	VERNON	1.6	0.1	N	N
WINDHAM	DOVER GREEN CONDOMINIUM	DOVER		0.1	Y	
WINDHAM	SUNTEC FOREST CONDOMINIUM	DOVER	0.26	0.1	N	
WINDHAM	SNOWTREE CONDOMINIUM	DOVER		0.1	Y	
WINDHAM	TARA TOWNHOUSES	DOVER		0.1	Y	
WINDHAM	BEAR CREEK CONDOMINIUM	JAMAICA	0.11	0.1	N	
WINDHAM	MOUNTAIN SIDE CONDOMINIUM	LONDONDERRY	0.11	0.1	N	
WINDHAM	BEARS CROSSING WATER SYSTEM	DOVER	0.13	0.1	N	
WINDHAM	SMITH HAVEN CENTER	LONDONDERRY		0.1	Y	
WINDHAM	GLEN RUN CONDOMINIUM	DOVER		0.1	Y	
WINDHAM	TIMBERCREEK CONDOMINIUM	DOVER		0.1	Y	
WINDHAM	CHARETTE WATER SYSTEM	DUMMERSTON		0.1	Y	
WINDHAM	SNOW MOUNTAIN VILLAGE	DOVER	0.14	0.1	N	
WINDHAM	GREENSPRINGS	DOVER		0.1	Y	
WINDHAM	SEASONS ON MOUNT SNOW	DOVER		0.1	Y	
WINDHAM	COLD BROOK FD BASE AREA	WILMINGTON	0.44	0.1	N	
WINDHAM	DEER CREEK CONDOMINIUMS	DOVER	0.17	0.1	N	
WINDHAM	PUTNEY SCHOOL	PUTNEY		0.1	Y	
WINDHAM	MOUNTAINDALE	DOVER	0.16	0.1	N	
WINDHAM	VERNON HALL	VERNON	0.45	0.1	N	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
WINDHAM	VILLAGE AT SAWMILL FARMS	DOVER		0.1	Y	
WINDHAM	TRAILSIDE AT MAGIC MOUNTAIN	LONDONDERRY		0.1	Y	
WINDHAM	DEEPWOOD PARK	BRATTLEBORO				
WINDHAM	KINGSWOOD AT MOUNT SNOW	DOVER	0.26	0.1	N	
WINDHAM	BLACK MOUNTAIN PARK	BRATTLEBORO				
WINDHAM	GLEN PARK	BRATTLEBORO				
WINDHAM	PUTNEY WATER SYSTEM	PUTNEY		0.1	Y	
WINDHAM	BUTTERFIELD COMMON SENIOR HOUSING	DOVER		0.2	Y	
WINDHAM	HUCKLE HILL HOUSING	VERNON	0.29	0	N	
WINDHAM	SUNDANCE SUBDIVISION	DOVER	0.24	0	N	
WINDHAM	VALLEY CARES INC	TOWNSHEND	0.2	0.013	N	
WINDHAM	BOULDER RIDGE AT MT SNOW	DOVER	0.61	0.1	N	N
WINDHAM	OUTLOOK AT MOUNT SNOW	DOVER	0.18	0.1	N	
WINDSOR	SONNENBERG WATER SYSTEM	BARNARD		0.1	Y	
WINDSOR	BETHEL WATER DEPT	BETHEL		0.1	Y	
WINDSOR	CAVENDISH TOWN WATER SYSTEM	CAVENDISH		0.1	Y	
WINDSOR	CHESTER WATER DEPT	CHESTER		0.1	Y	
WINDSOR	HARTFORD WATER DEPT	HARTFORD	0.1	0.1	N	
WINDSOR	QUECHEE CENTRAL			0.1	Y	
WINDSOR	NORTH HARTLAND COOP WATER SYSTEM INC	HARTLAND		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
WINDSOR	LUDLOW VILLAGE WATER DEPT	LUDLOW	*			A
WINDSOR	OKEMO VILLAGE CONDOMINIUMS	LUDLOW		0.1	Y	
WINDSOR	OKEMO TRAILSIDE CONDOMINIUM	LUDLOW		0.1	Y	
WINDSOR	NORWICH FIRE DISTRICT 1	NORWICH	*			A
WINDSOR	ROCHESTER WATER SYSTEM	ROCHESTER		0.1	Y	
WINDSOR	ROYALTON FIRE DISTRICT 1	ROYALTON		0.1	Y	
WINDSOR	ROYALTON TERRACE	ROYALTON		0.1	Y	
WINDSOR	SPRINGFIELD WATER DEPT	SPRINGFIELD	*			A
WINDSOR	CHALET VILLAGE	STOCKBRIDGE		0.05	Y	
WINDSOR	ASCUTNEY FIRE DISTRICT #2	WEATHERSFIELD		0.1	Y	
WINDSOR	WINDSOR WATER DEPT	WINDSOR		0.1	Y	
WINDSOR	MOUNT ASCUTNEY MHP	WINDSOR	0.2	0.1	N	
WINDSOR	WOODSTOCK AQUEDUCT CO	WOODSTOCK		0.1	Y	
WINDSOR	DIVIDED SKY FOUNDATION	LUDLOW		0.1	Y	
WINDSOR	ALPEN MEADOWS	LUDLOW	0.11	0.1	N	
WINDSOR	BIRCHWOOD CONDOMINIUM ASSOCIATION	HARTFORD		0.1	Y	
WINDSOR	TALL TIMBERS MHP	HARTFORD		0.1	Y	
WINDSOR	WINDY HILL ACRES MHP	SPRINGFIELD		0.1	Y	
WINDSOR	WOODSIDE MANOR	HARTFORD		0.1	Y	
WINDSOR	BRIDGEWATER MILL	BRIDGEWATER	0.1	0.1	N	
WINDSOR	MERRIMAC MANOR MHP	HARTFORD		0.1	Y	

County	WS Name	Town	F Level mg/L	Detection Limit mg/L	Below Detection, Yes (Y) or No (N)	Category
WINDSOR	ROUND TOP	PLYMOUTH		0.1	Y	
WINDSOR	NORWICH MEADOWS	NORWICH		0.1	Y	
WINDSOR	BLAKE HILL	WOODSTOCK		0.1	Y	
WINDSOR	LEDGES SYSTEM 1	PLYMOUTH		0.1	Y	
WINDSOR	WEST WINDSOR MOUNTAIN WATER SYSTEM	WEST WINDSOR	0.13	0.1	N	
WINDSOR	BULL RUN	LUDLOW		0.1	Y	
WINDSOR	WINTERPLACE WATER SYSTEM	LUDLOW		0.1	Y	
WINDSOR	TUCKERVILLE MHP	LUDLOW		0.1	Y	
WINDSOR	LEDGEWOOD	LUDLOW		0.1	Y	
WINDSOR	STARLAKE VILLAGE LEASEHOLDERS ASSOC	NORWICH		0.1	Y	
WINDSOR	OLCOTT FALLS MANOR MHP	HARTFORD				
WINDSOR	SOLITUDE WATER SYSTEM	LUDLOW	0.11	0.1	N	
WINDSOR	STERLING SPRING	HARTFORD				
WINDSOR	BLACK RIVER OVERLOOK	LUDLOW		0.1	Y	
WINDSOR	BIRCH LANDING CONDOMINIUM	PLYMOUTH		0.1	Y	
WINDSOR	CHAMBERS MOBILE HOME VILLAGE	HARTFORD				
WINDSOR	COBB HILL COHOUSING INC	HARTLAND		0.1	Y	
WINDSOR	JACKSON GORE OKEMO	LUDLOW	0.1	0.1	N	
WINDSOR	SOUTH FACE VILLAGE AT OKEMO	LUDLOW		0.1	Y	